



GST No. : 09AAAAF0094J1ZQ
 Labour Lic No. 21/4256
 P.F. No. UPVN/45219



FIRE SAFETY ENGINEERS

(An ISO 9001 : 2008 CERTIFIED COMPANY)

Regd. Off. : 95-A, Dondipur, Prayagraj-211003 (U.P.) India Mob. : 9415252922, 6393537793
 E-mail : firesafety786@yahoo.co.in

Ref: FSE/7864/Fire Insp/Report/2023-24

Date: 07.08.2023

Building Fire Safety Inspection Report Card

This is to certify that M/s Fire Safety Engineers, 95-A Dondipur, PRAYAGRAJ (U.P.) has inspected and serviced the fire extinguishers for Ford School & College, Kazipur, Naini Prayagraj-211008

Name of Building	Date of Inspection	Next due of Date Inspection	Capacity	Qty.	Type	Remark
Ford School & College, Ground floor & First floor Chemistry lab. Bio lab. Computer lab. Library lab. Corridor office. Exit Door store Room	03.08.2023	07.08.2024	05 kg & 4.5 kg	26 Nos 02 No. 04 Nos.	ABC CO2 Fire Bell Hose reel	OK OK OK OK
	N/A	N/A	05 kg & 4.5 kg	34 Nos	N/A	N/A

Inspection of fire safety equipment check list & summary
 Ford School & College, was surveyed for fire safety by M/s Fire Safety Engineers. Fire extinguishers have a crucial role in ensuring fire safety. The purpose of this survey was to identify significant fire safety issues which will be further
 1- Fire extinguisher is in fully charged & tagged
 2- Pressure gauge is in the green Area
 3- Fire extinguisher tags are current
 4- The tags expires one year from date of inspection
 5- parking Area is safe zone
 6- the Building exit door are safe
 All fire extinguishers are working condition & fully charged

Pranjal Singh
 Team Lead

Design, Supply, Installation & Maintenance of:
 Fire Alarm, Smoke Detection, Sprinkler, Wet Riser, Dry Riser, Foam, Dry Powder, CO2, Halon Fire Extinguisher, HVWS, Building Management, Security Equipment, CCTV, Access Control System